

VARIATION

EC TYPE EXAMINATION CERTIFICATE N^R ISSeP08ATEX027X/2

(14) Equipment or protective system:
 Flow switches type M...

- (15) Object of the variation:
- To permit other temperature classes in relation to other temperature ranges
 - Changing of the compound for DURALCO 4461 for high temperature models
 - The codes become :
 - o Ex ia IIC T6...T3 Ga
 - o Ex ia IIC T95°C...T175°C Da

Electrical parameters: Unchanged

Eventual prescriptions: Tamb : up to +149°C

(16) Report n^r : 14112 of 18.12.2014

Composed in total of 10 pages, completed with the following documents:

- "M-50X Explosion Proof Flow Switch with In-line Flow", DOC# M-50X DS 418121 (7 pages)
- "M-60X Explosion Proof Flow Switch with In-line Flow", DOC# M-60X DS 418121 (7 pages)
- "M-100X Explosion Proof Adjustable Flow Switch with Right Angle Flow", DOC# M-100X DS 418121 (7 pages)
- "M-200X Explosion Proof Adjustable Flow Switch with Right Angle Flow", DOC# M-200X DS 418121 (7 pages)
- The drawings

Number	Rev.	Date	Description
LABEL-ATEX-A-009	000	16.12.2014	M-100X Label
LABEL-ATEX-A-010	000	16.12.2014	M-200X Label
LABEL-ATEX-A-011	000	16.12.2014	M-50X/60X Label

This document may not be used without the original certificate

VARIATION

EC TYPE EXAMINATION CERTIFICATE N^R ISSeP08ATEX027X/2

- (17) Special conditions for safe use:
 The conditions imposed by the original certification are modified as follow:

Symbol X

- The integral cable connection shall be done either in non-hazardous area, or in an enclosure assuring a normalized protection mode.
- The material shall be supplied by a certified associated apparatus having the following maximum electrical parameters: 30V and 0.7W.
- The temperature classification in relation to the ambient temperature range :

Ambient temperature range	Temperature class for Gas	Temperature class for Dust
- 40 °C to + 60 °C	T6	T95°C
- 40 °C to + 75 °C	T5	T95°C
- 40 °C to + 117 °C	T3	T140°C
- 40 °C to + 149 °C	T3	T175°C

- The metallic enclosure shall be connected to earth.
- All precautions shall be taken in order to avoid all impacts or frictions on the aluminum parts of the enclosure which can induce the ignition of the explosive atmosphere.

- (18) Essential Health and Safety Requirements: Covered by the Standards listed in the variation 1

Colfontaine, 12.01.2015

INSTITUT SCIENTIFIQUE DE SERVICE PUBLIC
 Zoning A. Schweitzer, rue de la Platinerie
 B-7340 Colfontaine (Wasmès)
 Tel: ++ 32 65 610811 – Fax: ++ 32 65 610808
 e-mail : colfontaine@issep.be



M. Lambert
 Directeur

This document may not be used without the original certificate